



Kathleen Sebelius, Governor  
Roderick L. Bremby, Secretary

DEPARTMENT OF HEALTH  
AND ENVIRONMENT

[www.kdheks.gov](http://www.kdheks.gov)

## ADDENDUM

**IFB Number:** 264-07-04  
**Addendum No:** 1  
**Date Posted:** April 19, 2007  
**Closing Date:** 9:00 AM, April 30, 2007  
**Procurement Officer:** Kelly Chilson  
**Telephone:** 785-296-1519  
**E-Mail Address:** [kchilson@kdhe.state.ks.us](mailto:kchilson@kdhe.state.ks.us)

**Item:** Project Lead Safe KCK – Lead Hazard Reduction

### Conditions:

- (1) The contractor shall remove all burglar bars & awnings, but it is the homeowner's responsibility to re-install if they wish.
- (2) All window AC units must be re-installed in new windows. If the unit does not fit, it is the responsibility of the contractor to provide a unit that is new or in perfect working condition. The homeowner must approve a used unit.
- (3) ALL bare wood shall be primed with an oil-based primer.

### **6418 Oak Drive**

Install rubber treads at basement stairs. (Stairs must be scraped & painted)  
Total of 9 windows to be R & R. The bathroom window shall contain "obscure" glass  
Rear door shall be ½ glass

### **3027 N 31<sup>st</sup> St**

Wet-scrape, prime & paint all exterior wood surfaces, except front porch floor and skirt boards  
2 double-hung windows, Side C, in the basement shall be R & R. Total # of windows is 19  
Replace lattice work, Side D with ½" CCA lattice.

### **1816 Rowland**

Remove gutters & downspouts.  
Install fascia board, prime & paint at all sides of home & at 2<sup>nd</sup> story.  
Replace gutters & downspouts with seamless guttering, including guttering on 2<sup>nd</sup> story.  
R & R front door & jamb. Door shall be pre-hung steel door with ½ circle for light

### **24 N Mill**

Scrape & paint enclosed rear porch walls & ceiling

**There are no other changes at this time.**

Kelly Chilson  
Procurement Manager  
Kansas Department of Health & Environment  
1000 SW Jackson, Suite 570  
Topeka KS 66612